



JODEM OIL SERVE LIMITED

#10, Worlu Close, Behind Eko-oil filling Station, Eneka Air-Port Road

P.O. Box 5196, Port Harcourt, Rivers State.

Tel: 08038890389, 08121997588

E-mail: jodemoilserve ltdng@live.com

HYDROSTATIC TEST CERTIFICATE

CLIENT: TAMROSE LIMITED

VESSEL NAME: TMC EVOLUTION

DATE OF ISSUE: 16TH FEBRUARY, 2022

CERT. NO: JOL/TMC/PT/018/22

UNIT UNDER TEST: CARGO HOSE (FUEL HOSE)
SERIAL NUMBER: SH/TRVL-010
SIZE: 4"
LENGTH: 30M
WORKING PRESSURE: 150 PSI
TEST PRESSURE: 180 PSI

TEST PARAMETER

TYPE OF TEST: HYDROSTATIC (Water Medium)

EQUIPMENT USED	MANUFACTURER	SERIAL NUMBER	CAPACITY/RANGE
Hydro-Test Pump	Haskel	5176/28TR	0-300 PSI
Chart Recorder	ITT Barton	78BS-4719	24 Hours

APPLICABLE STANDARD:

The equipment was visually inspected and pressure tested in accordance with BS EN ISO 8032:1999

RESULT:

The hose was tested satisfactorily to 180 PSI for a period of 15 minute in accordance with the standard. As at the time of this survey, the equipment was found fit for its intended use within the operating parameters.

Validity: This certificate is valid for a period of Six Months Only

Next Due Date: 15TH AUGUST, 2022

CERTIFICATION: ACCEPTED

CHECKED AND APPROVED

GABRIEL OBA

