

Email: marobetashngltd@yahoo.com, kosmonbetashngltd@yahoo.com

PHONE: +2348032741369, +2348064616571

52 TRANS AMADI INDUSTRIAL LAYOUT

PORT HARCOURT

RIVERS STATE.

METER CALIBRATION CERTIFICATE

CLIENT: TAMROSE LIMITED

VESSEL: TMC BALD EAGLE

DATE OF ISSUE: 15th August, 2022Cert. No: BNL/TL/FOCAL/011^A-22**UNIT UNDER TEST (UUT):****DESCRIPTION:**

F O Flow Meter

MAKE:

NITTO FLOW METER

MODEL:

RSA0080B0FFM43450010R

SERIAL NO:

0258586

ID NUMBER:

BNL/TL/011

TAMPER PROOF SEAL NO:

TL-011

MAX. RATE OF FLOW:50m³/h**MIN. RATE OF FLOW:**5m³/h**WORK PRESSURE**

10 BAR

UNIT OF FLOW:m³/h**PRODUCT DELIVERED:**

Diesel

TEMP. MIN/MAX:

-10/120°C

SIZE:

3"

TRACEABILITY:

This flow meter was calibrated against ANSI/NCSL Z540.3 and is Traceable to NIST, in accordance with ASTM E4 and verify that it conforms to Accuracy Grade 3A (0.25%) over the entire scale.

REMARKS:

The calibration was performed using direct comparison with a certified instrument. The uncertainty of measurement is based on a standard uncertainty multiplied by a coverage factor K=2 providing a level of confidence of approximately 95%. The instrument is okay for use.

The Test Results are as follows:

Product	Standard Used L/min	Meter Under Test Reading m ³ /h	Vol. Flow Rate Q = m ³ /s	Average Error ± %
Diesel	500	0.500	100	0.1
Diesel	1000	1.000	100	0.1
Diesel	1500	1.500	100	0.1
Diesel	2500	2.500	100	0.1

Meter Factor: 1.000

VALIDITY: This Certificate is valid for a period of Six months only.

NEXT DUE DATE: 14th February, 2023

MANUFACTURED YEAR: 2019

CERTIFICATION:

ACCEPTABLE

CHECKED / APPROVED



Department Of Petroleum Resources
PERMIT NO: DPR/OGISP/20/1730288/N199823
DPR/OGISP/20/1766626/N199274